TOTO_®

CST412MF.10

Aquia® Close Coupled Toilet, 1.6GPF & 0.9GPF

FEATURES

- Dual-Max[®] flushing system, high-efficiency (1.6GPF/6.0LPF & 0.9GPF/3.4LPF)
- Elongated bowl
- Universal Height
- Close coupled, elongated front bowl and tank set, less toilet seat
- Chrome push-button
- 10" rough-in

MODELS

• CST412MF.10

COMPONENTS

- CT412F.10 Elongated Front Bowl, 10" rough-in
- ST412M Tank and Cover only
- SS204 SoftClose[®] seat (sold separately)
- SS114 SoftClose seat (sold separately)
- THU9090R Washlet[®] Adapter Hose Kit (Required for Washlet installation)

COLORS/FINISHES

 Standard #01 Cotton

PRODUCT SPECIFICATION

The two-piece, high-efficiency, universal height, Dual-Max flushing system toilet shall be 1.6GPF/0.9GPF. Toilet shall have 10" rough-in. Toilet shall have highprofile tank, elongated front bowl and chrome pushbutton. Toilet shall be TOTO Model CST412MF.10#01.



D+ Dual-Max

CODES/STANDARDS

- Meets and exceeds ASME A112.19.2/CSA B45.1, ASME A112.19.14
- Certifications: IAPMO(cUPC[®]), EPA WaterSensesm, State of Massachusetts, and others
- Code compliance: UPC, IPC, NSPC, NPC Canada, and others
- Legislative compliance: California Green Building Code, City of Los Angeles Water Efficiency Ordinance, and others



CST412MF.10

Aquia® Close Coupled Toilet, 1.6GPF & 0.9 GPF

SPECIFICATIONS

• Water Use

1.6 GPF & 0.9GPF (6.0 LPF & 3.4LPF)


- (O.U LPF (
- Flush System Dual-Max[®] Min. Water Pressure 8 psi (flowing)
- Water Surface 6" x 4-1/2"
- Trap Diameter 2-1/8"
- Rough-in 10"
- Trap Seal 2
- Warranty
- Material
- 2-1/8" One Year I
- ty One Year Limited Warranty al Vitreous china
- Shipping Weight CT412F.10 78lbs
- Shipping Weight C1412F.10 780 ST412M - 30lbs
- Shipping Dimensions CT412F.10
 - 30-3/4" L x 17-3/8" W x 20-1/2" H

ST412M 17-1/4" L x 7-7/8" W x 17-1/2" H


INSTALLATION NOTES

Back-to-Back Toilet Installations:

TOTO recommends the use of a nationally listed, double sanitary tee-wye only, in vertical waste stacks, in accordance with the stipulations noted in the majority of nationally recognized plumbing codes.



To maintain adequate wall gap between the back of the tank and wall, mount the floor flange at a nominal 10" rough-in distance.



These dimensions and specifications are subject to change without notice